



**GENERAL NOTES:**

1. FLOOR SLAB TO BE 5" THICK OF 3K CONCRET WITH .008 POLYTHENE SHEETING UNDER ON 3" THICK SAND BED. SLAB TO BE REINFORCED WITH A.S. N6 603 FABRIC HAVING 1" COVER TO TOP OF SLAB.
2. THE WHOLE OF THE OUTSIDE FACE OF EXTERNAL WALLS TO BE COVERED WITH SISALATION 450 PRIOR TO FIXING EXTERNAL SHEETING. SISALATION 453 SHALL BE LAID ACROSS ROOF TRUSSES & PORCH RAFTERS THEN DISHED 3" PRIOR TO FIXING ROOF BATTENS OVER WHOLE OF ROOF AREA.
3. WINDOW SIZES AS SHOWN ARE APPROX. ONLY.

MAUNSELL & PARTNERS PTY. LTD.  
CONSULTING ENGINEERS

TENDER DRAWING ONLY  
NOT FOR CONSTRUCTION USE

REV.	DATE	DESCRIPTION

**KING ISLAND SHEELTE LTD.**  
PORT AT LITTLE GRASSY BAY

**GENERAL ARRANGEMENT**  
**OFFICE & AMENITIES BUILDING**

**MAUNSELL & PARTNERS PTY. LTD.**  
CONSULTING ENGINEERS

SCALE: AS SHOWN	<b>DRG. No. 2070/501</b>
DATE: MARCH 1971	
DATE OF ISSUE: A.N.F.	
16 APR 1971	