

DESCRIPTION	SPECIFICATION
<b>Fire Hydrant System (No of Outlets)</b> Pumps, output	26 outlets Two (2) 3 x 4 centrifugal, 700 GPM
<b>Portable Fire Extinguishers</b> Type Number	CO <sub>2</sub> and dry chemical 96
<b>Combustible Gas Detection System</b> Manufacturer	Texas Analytical Systems
<b>Smoke and Fire Detection System</b> Manufacturer Type	Henschel TM
<b>Complete Fireman's Outfits to Include</b> Breathing apparatus Fire proof suits, fire axe etc Location	Two (2) Pilot House/Motor Room
<b>Helideck Foam System</b> Foam/water monitors	Dry chemical and 200 gal fixed foam system per USCG requirement
<b>Survival Suits</b> Manufacturer Quantity Location on Unit	Imperial Mfg 90 Each Bunk/Sick Bay
<b>Breathing Apparatus</b> Escape packs Self contained breathing apparatus (30 min duration)	Four (4) Scott air packs w/14 extra bottles
<b>Emergency Shutdown System/ Inert Gas Flooding System</b>	Electric kill switch Sliding gate valves on main engines