



# Material Test Results

2/6 Kilowatt Court, Ulverstone, Tas 7315

Ph (03) 6334 0834

ACN 623 420 226

Client	Gaspersic Contracting
Project	Quality Assurance Testing
Location	Snake Ridge
Project No	RE058/22/3U
Sample No	U22/1066c
Date Received	23/11/2022
Date Tested	24-29/11/2022
Sample Identification	LSRB #3
Sampled By	Client - Tested As Received
Sample Description	Crushed Rock Screenings
Test Report No	RE058/22/3U/AF

Test Description	Details	Results
Los Angeles Value AS 1141.23	Test Grading	A
	Remarks	
	Los Angeles Value	26
	Remarks	

 <p>Accredited for compliance with ISO/IEC 17025 - Testing</p> <p>World Recognised Accreditation</p>	Laboratory Accreditation No 20328	 Approved Signatory (M.I. Ansell)	1/12/2022 Date of Issue
---	-----------------------------------	---	----------------------------